



NATA Accredited Laboratory

Accreditation No: 15305

Accredited for compliance with
ISO/IEC 17025 - Testing

Laminex[®]

a division of Laminex Group Pty Ltd ABN 98 004 093 092

The Laminex Group Technology Centre

Postal Address: PO BOX 720, Wendouree, Vic 3355

Address: 22 Trewin St, Wendouree, Vic 3355

Telephone: (03) 5337 3613

Fax: (03) 5337 3647

Test Report No.
20PB-Floor

Date of Issue
28/08/2020

Client:
Laminex Australia
Lot 2 Moore Rd
Dardanup
WA 6236

This test report shall not be reproduced, except in full,
without written approval from The Laminex Group Technology Centre

The material contained in this report is confidential to the entity identified as 'Client' above.

As the sample(s) have been provided by the client, the results contained in this report apply only to the sample(s) as received.

Test Report No. 20PB-Floor

Date of Issue: 28/08/2020

Laminex Sample Reference No.	25778
Client Sample Reference No.	770770
Product:	19mm Particleboard Flooring General Purpose, Class 1, E1
Surface Treatment	None (Raw)
Receive Date:	15/04/2020
Condition:	Good.
Testing Performed Date(s):	22-24/4/2020
Specification Standard	AS/NZS 1860.1:2017
Product Classification	Class 1, E1 Particleboard Flooring

Test	Method	Unit	Result		Product limit		Compliance
			Mean	Std Dev	Limit Value	Standard Clause	
Formaldehyde Emission	AS/NZS 4266.1: 2017 Section 17	mg/L	1.08	0.04	Maximum 1.5 (E1)	Clause 6.3 Table 1	PASS E1

Formaldehyde Emission Class: E1

Comments
As agreed to by the client, compliance to product limits is based solely on the reported test result(s) and no uncertainty of measurement shall be taken into account.

Approved Signatory:

Laboratory Manager (J. Smolenaers)...



Test Report No. 20PB-Floor

Date of Issue: 28/08/2020

Laminex Sample Reference No.	26155
Client Sample Reference No.	781660
Product:	22mm Particleboard Flooring General Purpose, Class 1, E1
Surface Treatment	None (Raw)
Receive Date:	15/06/2020
Condition:	Good.
Testing Performed Date(s):	6-8/07/2020
Specification Standard	AS/NZS 1860.1:2017
Product Classification	Class 1, E1 Particleboard Flooring

Test	Method	Unit	Result		Product limit		Compliance
			Mean	Std Dev	Limit Value	Standard Clause	
Formaldehyde Emission	AS/NZS 4266.1: 2017 Section 17	mg/L	0.77	0.03	Maximum 1.5 (E1)	Clause 6.3 Table 1	PASS E1

Formaldehyde Emission Class: E1

Comments
As agreed to by the client, compliance to product limits is based solely on the reported test result(s) and no uncertainty of measurement shall be taken into account.

Approved Signatory:

Laboratory Manager (J. Smolenaers)...



Test Report No. 20PB-Floor

Date of Issue: 28/08/2020

Laminex Sample Reference No.	26125
Client Sample Reference No.	778984
Product:	19mm Particleboard Flooring Termite Treated, Class 1, E1
Surface Treatment	None (Raw)
Receive Date:	10/06/2020
Condition:	Good.
Testing Performed Date(s):	23-25/06/2020
Specification Standard	AS/NZS 1860.1:2017
Product Classification	Class 1, E1 Particleboard Flooring

Test	Method	Unit	Result		Product limit		Compliance
			Mean	Std Dev	Limit Value	Standard Clause	
Formaldehyde Emission	AS/NZS 4266.1: 2017 Section 17	mg/L	1.00	0.02	Maximum 1.5 (E1)	Clause 6.3 Table 1	PASS E1

Formaldehyde Emission Class: E1

Comments
As agreed to by the client, compliance to product limits is based solely on the reported test result(s) and no uncertainty of measurement shall be taken into account.

Approved Signatory:

Laboratory Manager (J. Smolenaers)...



Test Report No. 20PB-Floor

Date of Issue: 28/08/2020

Laminex Sample Reference No.	26248
Client Sample Reference No.	2016923
Product:	22mm Particleboard Flooring Termite Treated, Class 1, E1
Surface Treatment	None (Raw)
Receive Date:	10/07/2020
Condition:	Good.
Testing Performed Date(s):	27-29/07/2020
Specification Standard	AS/NZS 1860.1:2017
Product Classification	Class 1, E1 Particleboard Flooring

Test	Method	Unit	Result		Product limit		Compliance
			Mean	Std Dev	Limit Value	Standard Clause	
Formaldehyde Emission	AS/NZS 4266.1: 2017 Section 17	mg/L	1.16	0.03	Maximum 1.5 (E1)	Clause 6.3 Table 1	PASS E1

Formaldehyde Emission Class: E1

Comments
As agreed to by the client, compliance to product limits is based solely on the reported test result(s) and no uncertainty of measurement shall be taken into account.

Approved Signatory:

Laboratory Manager (J. Smolenaers)...

