

Emission Test Certificate

Friday, September 19th, 2014

Supplier: The Laminex Group (22 Trewin St, Wendouree, VIC 3355)

Sample Description: Decorated E1 Particleboard (Reference: 15618)

Date Tested: September 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Green Building Council of Australia Green Star Office Interiors v1.1 IEQ-11	Decorated E1 Particleboard
Total Volatile Organic Compound Emission Rate limit <math><0.5\text{mg}/\text{m}^2/\text{hr}</math>	Total Volatile Organic Compound Emission Rate: $0.260\text{mg}/\text{m}^2/\text{hr}$

The above results can be considered to be representative of the Laminex Vertiboard, Formica Colourpanel and Trade Essentials Whiteboard products.



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV140901